

## AUXILIARY BACK-UP SYSTEM

Furnish and Install Auxiliary "Back-up" pump to activate automatically in the event of power failure or failure of primary pump. Auxiliary Back-up System may be either battery or water powered meeting the following specifications:

### Battery Powered:

- a. Pump to be a Blue Angel Model BSP12, Wayne Model ESP12, Zollar Model 505, or approved equivalent.
- b. Furnish and install a minimum 105 amp hour deep cycle 12 volt battery.

### Water Powered:

- a. Furnish and install a water powered automatic "back-up" pump. Pump to be a home Gaurd Model 14000 or approved equivalent. All water powered systems must include a dual check backflow preventer installed in the supply line. Valve to be a Watts #7 or approved equivalent. Installation must conform to local codes.

SMPMP.specs